CONNECTION SCHEDULE					
ITEM	DESCRIPTION	LOCATION	MAX. FLOW	CONNECTION	MATERIAL
A	HARD WATER INLET	WATER SOFTENER	GPM	NPT	BRASS
B	SOFT WATER OUTLET	WATER SOFTENE	GPM	NPT	BRASS
C	WASTE TO DRAIN	WATER SOFTENER	GPM	NPT	GALV

DIMENSIONS		
LENGTH	WIDTH	HEIGHT

NOTES:

1. ALL PIPING, FITTINGS, ETC SHOWN WITH HIDDEN LINES ARE PROVIDED BY OTHERS.
2. GENERAL PLUMBING CONNECTIONS ARE SHOWN FOR CLARITY ONLY.
3. PRESSURE VESSELS ARE 100 PSI NON-CODE CONSTRUCTION WITH EPOXY LINED INTERIOR AND FINISH PAINTED PAINTED EXTERIOR.
4. PRESSURE VESSEL INTERIOR DISTRIBUTION SYSTEM IS SCH 80 PVC.
5. SOFTENER RESIN AND SUPPORT GRAVEL IS SHIPPED SEPERATELY AND IS TO BE LOADED AFTER INSTALLATION.
6. FLECK VALVES HAVE NXT2 CONTROLLERS.









PRELIMINARY - NOT FOR CONSTRUCTION

THIS DOCUMENT CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION THAT CANNOT BE REPRODUCED OR DIVULGED, IN WHOLE OR PART, WITHOUT AUTHORIZATION IN WRITING FROM MARLO INCORPORATED, RACINE, WI.

REVISIONS			
NO.	DATE	BY	REMARKS

MARLO INCORPORATED

FRAC. ± DEC. ±	
SCALE	
DRN. Anthony	
CHECKED	
APP'D.	
DATE 12/3/2019	
SHEET 1 OF 1	

MST DUPLEX ALT SOFTENER - TOP MOUNT
GENERAL ARRANGEMENT

DRAWING NO. 5-310 01 REV.